

U.S. Department of Veterans Affairs

PROJECT LOCATION: JESSE BROWN VA MEDICAL CENTER 820 S. DAMEN AVENUE CHICAGO, ILLINOIS 60612 312.569.8387

PROJECT TITLE: INTERIOR ARCHITECTURAL CONSTRUCTION AT BUILDING 5


BUILDING NUMBER: 5

ARCHITECTS + ENGINEERS: BANCROFT ARCHITECTS + ENGINEERS

700 NICHOLAS BLVD. SUITE 403 ELK GROVE VILLAGE, IL 60007 847.952.9362 www.bancroft-ae.com

PROJECT NUMBERS:

IDIQ NO. VA69D-13-D-0042 CONTRACT NO. VA69D-14-J-3280 STATION PROJECT NO. 537-13-122 BANCROFT-AE PROJECT NO. 13-105-08



SHEET INDEX						
DRAWING NUMBER	DRAWING TITLE					
G-000	COVER					
G-001	GENERAL NOTES, SYMBOLS AND ABBREVIATIONS					
SITE						
AS-101	SITE PLANS- DEMOLITION AND NEW					
ARCHITECTURAL						
AD-101	FIRST FLOOR, PARTIAL BASEMENT, AND REFLECTED CEILING DEMOLITION PLANS					
A-101	FIRST FLOOR PLAN/ PARTIAL BASEMENT PLAN AND FIRST FLOOR REFLECTED CEILING PLAN					
A-201	ELEVATION, SECTIONS, AND DETAILS					
A-301	DOOR SCHEDULE, DETAILS AND ROOM FINISH SCHEDULE					
A-401	DEDUCT ALTERNATES - FIRST FLOOR PLAN AND EXTERIOR STAIRS					
STRUCTURAL	•					
S-101	RAMP FOUNDATION PLAN AND DETAILS					
S-102	FOUNDATION SECTIONS					
S-103	STRUCTURAL GENERAL NOTES					
ELECTRICAL						
E-001	ELECTRICAL NOTES AND SYMBOLS					
EP-101	EXISTING POWER/DATA PLANS					
EP-102	ELECTRICAL POWER PLAN AND LIGHTING PLAN					
E-200	ELECTRICAL DETAILS AND SCHEDULES					

IDIQ NO. VA69D-13-D-0042

CONTRACT NO. VA69D-14-J-3280 Project Number Drawing Title SITE PLAN: ENGINEERS + CONSULTANTS: ARCHITECT + ENGINEERS: Office of COVER INTERIOR ARCHITECTURAL #537-13-122 CONSTRUCTION AT BUILDING 5 Building Number Construction **(** and Facilities Approved: Project Director 700 Nicholas Blvd. Suite 403 Drawing Number Management Elk Grove Village, IL 60007 CHICAGO, IL T:847.952.9362 F:847.952.9403 G-000 08/04/2016 ISSUED FOR SOLICITATION Checked www.bancroft-ae.com BANCROFT ARCHITECTS + ENGINEERS 12/03/2015 ISSUED FOR BIDS Bancroft-AE Project No. 13-105-08 12/03/2015 Revisions:

GENERAL NOTES - PAINTING

- P1. PROVIDE ALL PAINTING AND RELATED WORK AS SHOWN ON THE DRAWING AND/OR AS REASONABLY IMPLIED BY THE SPECIFICATIONS AND THE PROJECT REQUIREMENTS TO PROVIDE A COMPLETELY FINISHED PROJECT.
- P2. ALL SCRATCHES, DENTS, CRACKS AND/OR OPENINGS ON EXISTING AND NEW WALL SURFACES ARE TO BE FILLED WITH PLASTER PATCH, SPAKLING COMPOUND OR OTHER PRESCRIBED MATERIAL IN AN INDUSTRY APPROVED MANNER AND SANDED SMOOTH TO PROVIDE A "LIKE NEW" SURFACE CONDITION BEFORE PAINTING AND FINISHING.
- P3. ALL SURFACES ARE TO BE CLEANED FREE OF LOOSE DIRT, DUST, OIL, GREASE AND ALL FOREIGN MATTER JUST PRIOR TO FINISHING.
- P4. PROVIDE ALL LABOR, MATERIALS, BRUSHES, TOOLS, LADDERS AND ALL EQUIPMENT OF ANY KIND NECESSARY FOR PROPER EXECUTION OF THE WORK.

- P5. WORKMANSHIP SHALL BE FIRST CLASS IN EVERY RESPECT WITH ALL MATERIALS EVENLY SPREAD AND SMOOTH WITHOUT RUNS, SAGS, OR DEBRIS IN THE FINISHED SURFACE.
- P6. THE PRIME COAT SHALL BE TINTED TO APPROXIMATE SHADE OF FINAL COAT. ALL SECTIONS, SPOTS OR HOT SPOTS AFTER PRIMARY APPLICATION SHALL BE TOUCHED-UP BEFORE APPLYING THE SECOND COAT TO PRODUCE A SMOOTH AND LEVEL SURFACE. THE FINAL COAT SHALL NOT BE APPLIED UNTIL AFTER ALL OTHER TRADES, WHOSE OPERATIONS WOULD BE DETRIMENTAL TO FINISH PAINTING, HAVE FINISHED THEIR WORK IN THE AREAS TO BE PAINTED.
- P7. WORK NOT INCLUDED: UNLESS OTHERWISE INDICATED, SHOP PRIMING OF FERROUS METAL ITEMS AND FABRICATED COMPONENTS ARE INCLUDED UNDER THEIR RESPECTIVE TRADES. PRE-FINISHED ITEMS ARE NOT INCLUDED. FINISHED METALS SUCH AS ANODIZED ALUMINUM, STAINLESS STEEL, BRONZE, AND SIMILAR METALS WILL NOT BE PAINTED, UNLESS OTHERWISE SPECIFIED. DO NOT PAINT ANY MOVING PARTS OF OPERATING UNITS, OR OVER ANY EQUIPMENT IDENTIFICATION, PERFORMANCE RATINGS, NAMES OR NOMENCLATURE PLATES OR CODE-REQUIRED LABELS.
- P8. PROTECTION: PROTECT WORK OF OTHER TRADES. CORRECT ANY PAINTING RELATED DAMAGES BY CLEANING, REPAIRING OR REPLACING, AND REFINISHING, AS DIRECTED BY THE COR.
- P9. PROPERLY PREPARE ALL SURFACES TO RECEIVE FINISHES AND APPLY PRIME COATS, PAINTING AND FINISHING MATERIALS IN ACCORDANCE WITH EACH MANUFACTURER'S DIRECTIONS FOR A QUALITY APPLICATION. USE APPLICATORS AND TECHNIQUES BEST SUITED FOR MATERIALS AND SURFACES TO WHICH APPLIED.
- P10. APPLY ADDITIONAL COATS WHEN UNDERCOATS, STAINS OR OTHER CONDITIONS SHOW THROUGH FINAL PAINT OR FINISHED COAT. UNTIL THE SURFACE FILM IS OF UNIFORM FINISH COLOR AND APPEARANCE.
- P11. APPLY EACH MATERIAL AT NOT LESS THAN THE MANUFACTURER'S RECOMMENDED SPREADING RATE, TO PROVIDE A TOTAL DRY FILM THICKNESS OF NOT LESS THAN 2.5 MILS FOR ENTIRE COATING SYSTEM OF (1) PRIME AND (2) FINISH COATS FOR 3 COAT WORK ON PAINTED SURFACES.
- P12. PAINTED SURFACE PREPARATION COMPLY WITH PAINT MANUFACTURER'S RECOMMENDATIONS FOR EACH MATERIAL TYPE AND SURFACE FINISH AS PER THEIR REFERENCE GUIDE AND SPECIFICATIONS.
- P13. METAL SURFACE PREPARATION ALL METAL SURFACES TO BE PAINTED MUST BE CLEAN AND FREE OF RUST, MILL SCALE, GREASE, OIL, DIRT AND OTHER FOREIGN MATTER. ALL ALUMINUM MUST BE CLEANED WELL IN ORDER TO REMOVE ALL SURFACE FILM AND OILS, AND SHALL BE PROPERLY PRIMED IN ACCORDANCE WITH THE PAINT MANUFACTURER'S RECOMMENDATIONS.
- P14. STRIP EXISTING PAINT, GRIND AND REMOVE ALL RUST, CLEAN, PROVIDE (1) PRIME COAT & (2) FINISH COATS OF PAINT ON ALL EXISTING EXTERIOR METAL COLUMNS, GUARD RAILS, HAND RAILS & ALL EXPOSED MISCELLANEOUS METAL BRACKETS, PLATES, EXTERIOR METAL DOORS AND FRAMES, ETC.
- P15. PAINT ALL EXPOSED MECHANICAL DUCTS, DUCT INSULATION, PIPING, ELECTRICAL CONDUITS, SUPPORTS, BRACKETS, HANGERS, ETC. PRIME ALL ELEMENTS AS PER THE PAINT MANUFACTURER'S RECOMMENDATIONS AND PROVIDE (2) FINISH COATS APPLIED BY SPRAYED ON APPLICATION.

GENERAL NOTES TO CONTRACTOR(S)

(APPLIES TO ALL CONTRACTORS)

A. ALL WORK SHALL BE COMPLETED ACCORDING TO ALL PUBLISHED APPLICABLE LOCAL STATE FEDERAL AND NATIONAL CODES, ORDINANCES, REGULATIONS AND VA REQUIREMENTS.

B. EACH CONTRACTOR SHALL HAVE PUBLIC LIABILITY, PROPERTY DAMAGE AND WORKMAN'S COMPENSATION INSURANCE. CONSULT VA REQUIREMENTS FOR EXACT COVERAGE REQUIRED.

C. EACH CONTRACTOR SHALL COORDINATE WITH ALL OTHER CONTRACTORS. CHECK, PRIOR TO COMMENCEMENT OF WORK, FOR SPACE REQUIREMENTS WITH ALL OTHER TRADES.

D. RELOCATION OF DUCTS, PIPING, CONDUIT, ELECTRICAL BOXES WHICH MAY ALTER THE ARCHITECTURAL OR STRUCTURAL CONSTRUCTION MUST BE APPROVED BY THE COR, PRIOR TO RELOCATION. NO EXTRA PAYMENT WILL BE ALLOWED FOR WORK RESULTING FROM THESE CHANGES, WITHOUT APPROVALS.

MECHANICAL CONTRACT DRAWINGS SHALL BE TAKEN IN A SENSE AS DIAGRAMMATIC. SIZE & MEANS OF RUNNING PIPING ARE SHOWN BUT IT IS NOT INTENDED TO SHOW EVERY FITTING AND OFFSET. NOR EVERY STRUCTURAL DIFFICULTY THAT CAN BE ENCOUNTERED DURING THE INSTALLATION OF THE WORK.

. <u>EXAMINATION OF THE DRAWINGS, SPECIFICATIONS AND SITE:</u> BEFORE SUBMITTING A BID. THE BIDDERS SHALL CAREFULLY EXAMINE THE DRAWINGS AND SPECIFICATIONS SO AS TO BE THOROUGHLY FAMILIAR WITH ALL THE REQUIREMENTS. EACH BIDDER SHALL VISIT THE SITE OF THE WORK TO BECOME ACQUAINTED WITH ALL THE CONDITIONS AFFECTING THE CONTRACT, OBSTACLES WHICH MAY BE ENCOUNTERED AND ALL OTHER CONDITIONS RELATIVE TO THE WORK TO BE PERFORMED: AND, IF AWARDED THE CONTRACT, SHALL NOT BE ALLOWED ANY EXTRA COMPENSATION BY REASON OF ANY UNFORESEEN DIFFICULTIES OR OBSTACLES WHICH THE BIDDER COULD HAVE DISCOVERED OR REASONABLY ANTICIPATED PRIOR TO THE BUILDING. SHOULD ANY DISCREPANCIES, ERRORS, CONFLICT OR ITEMS NEEDING CLARIFICATION BE DISCOVERED IN THE PLANS AND/OR SPECIFICATIONS, THE CONTRACTOR SHALL NOTIFY THE COR PRIOR TO SUBMITTING A BID AND BEFORE STARTING

G. <u>CONTRACTOR'S SUPERVISION:</u> EACH CONTRACTOR SHALL MAINTAIN A COMPETENT FOREMAN OR DIRECT REPRESENTATIVE ON THE JOB AT ALL TIMES. THE CONTRACTOR SHALL COOPERATE WITH THE SUPERINTENDENT AND FOREMEN OF OTHER TRADES IN ORDER THAT THERE MAY BE NOT DELAY IN THE ERECTION AND COMPLETION OF THE WORK.

H. ADA/ABA ROOM SIGNS: PROVIDE AND 8"X8" PREMANUFACTURED SIGNAGE SYSTEM, SURFACE MOUNTED, AT EACH INTERIOR DOOR ADN CASED OPENING. COMPLY WITH ALL ADA BRAIL, IMAGERY AND MOUNTING REQUIREMENTS. PROVIDE SIGNS WITH FLEXIBLE ROOM NAME/USE TITLE BLOCK CHANGEABILITY. EACH SIGN SHALL INCLUDE A ROOM #, ROOM TITLE, ADA IMAGERY, IF REQUIRED AND THE BRAIL VERSION. COORDINATE ALL SIGNAGE REQUIREMENTS, COLOR SELECTIONS, MOUNTING LOCATIONS, FONT TYPE AND COLOR, ETC. PROVIDE A TOTAL OF (17) INDIVIDUAL SIGNS AND ALL RELATED WORK TO FULLY COORDINATE VA INFORMATION/REQUIREMENTS ALONG WITH ALL INSTALLATION.

ARCHITECTURAL BARRIERS ACT (ABA) COMPLIANCE

- PER CBC CHAPTER 18-11-1117.3.4 AND ICC/ANSI-A117.1- 2009 THE FOLLOWING COMPLY FULLY:
- 1. ACCESSIBLE ENTRY
- ACCESSIBLE MEN'S AND WOMEN'S TOILET ROOMS.
- ACCESSIBLE HI-LO DRINKING FOUNTAINS.
- 4. ALL CONTROLS AND OPERABLE PARTS FULLY COMPLY AND ARE BETWEEN 15" AND 48". 5. ALL SIGNAGE COMPLIES - IS OF BRAILLE AND TACTILE AND IS LOCATED ON THE DOOR HANDLE
- SIDE OF DOOR. INSTALLED AT APPROPRIATE HEIGHT AND DISTANCE FROM DOOR FRAME.

APPLICABLE CODES + STANDARDS

- ALL WORK SHALL COMPLY WITH THE FOLLOWING CODES;
- 1. VA DIRECTIVES, DESIGN MANUALS, MASTER SPECIFICATIONS, VA NATIONAL CAD STANDARD APPLICATION GUIDE, AND OTHER GUIDANCE ON THE TECHNICAL INFORMATION LIBRARY (TIL) (HTTP://WWW.CFM.VA.GOV/TIL/).
- 2. INTERNATIONAL BUILDING CODE (IBC) 2015
- NFPA 101 LIFE SAFETY CODE 2015
- 4. NFPA NATIONAL FIRE CODES WITH THE EXCEPTION OF NFPA 5000 AND NFPA 900
- OCCUPATIONAL, SAFETY AND HEALTH ADMINISTRATION (OSHA) STANDARDS. VA SEISMIC DESIGN REQUIREMENTS, H-18-8
- 7. NATIONAL ELECTRICAL CODE (NEC) 2014
- 8. NATIONAL STANDARD PLUMBING CODE (NSPC) 2015
- 9. ARCHITECTURAL BARRIERS ACT ACCESSIBILITY STANDARDS (ABAAS) INCLUDING VA SUPPLEMENT, BARRIER FREE DESIGN GUIDE (PG-18-13)

SPECIAL SAFETY NOTICE

ALL CONTRACTORS, SUBCONTRACTORS AND THEIR REPRESENTATIVES WORKING ON THIS PROJECT SHALL AT ALL TIMES PRIOR AND DURING THE COURSE OF THEIR ACTIVITY BE RESPONSIBLE FOR THE SAFETY OF THEIR EMPLOYEES AS WELL AS ALL OTHERS AND IN THE CARE OF THE PROPERTY AND THE PUBLIC WAY.


EACH CONTRACTOR OR SUBCONTRACTOR, AS REPRESENTATIVES OF THEIR EMPLOYEES, SHALL ASCERTAIN THAT THE CONDITIONS UNDER WHICH THEY WILL BE REQUIRED TO ACCOMPLISH THEIR WORK ARE SAFE AND MEET ALL REGULATIONS OF THE OCCUPATIONAL SAFETY AND HAZARD ACT OR OTHER GOVERNING REGULATIONS. THE BEGINNING OF WORK BY A CONTRACTOR OR SUBCONTRACTOR SHALL INDICATE SATISFACTION CONCERNING SAFETY AND FULL RESPONSIBILITY FOR ACCIDENTS, INJURIES, AND/OR DAMAGES.

IF UNSATISFIED, THE CONTRACTOR OR SUBCONTRACTOR SHALL INDICATE THE ACTIONS AND/OR DEVICES NECESSARY TO RENDER THE JOB-SITE SAFE. IF THE WORK OF OTHER PARTIES IS. UPON INSPECTION. FOUND AT ANY TIME TO BE UNSAFE THE CONTRACTOR OR SUBCONTRACTOR SHALL IMMEDIATELY STOP ALL WORK AND NOTIFY THE GENERAL CONTRACTOR AND COR. THE BID SUBMISSIONS AND BEGINNING OF WORK SHALL INDICATE ACKNOWLEDGMENT AND ACCEPTANCE OF THESE REQUIREMENTS.

BASIS OF DESIGN (BOD) PROTOCOLS

BASIS OF DESIGN COMPLIANCE:

- CONTRACTOR SHALL BE RESPONSIBLE TO VERIFY AND CERTIFY THAT THE CHARACTERISTICS OF THE EQUIPMENT OR MATERIAL HE/SHE WILL BE SUBMITTING FOR REVIEW MEETS OR EXCEEDS THE CAPACITY AND DUTY REQUIREMENTS AS SPECIFIED IN ANY OF THE "BASIS OF DESIGN" SPECIFICATION.
- IF THE EQUIPMENT OR MATERIAL BEING SUBMITTED FOR REVIEW WILL REQUIRE THAT MODIFICATIONS NEED TO BE MADE, TO THE WORK OF THE PROVIDING CONTRACTOR OR THE WORK OF OTHER CONTRACTORS, THE SUBMITTING CONTRACTOR SHALL BE FULLY RESPONSIBLE TO ADVISE/INFORM THE PRIME CONTRACTOR OF ANY AND ALL SUCH NECESSARY IMPACTS AND POSSIBLE DELAYS AND/OR COSTS AS A PART OF THEIR BID AND CONSTRUCTION SCOPE OF WORK RESPONSIBILITIES.
- THE SUBMITTING CONTRACTOR WILL BE FULLY RESPONSIBLE TO COORDINATE ALL DEVIATIONS FROM THE "BASIS OF DESIGN" INTENT WITH THE GENERAL CONTRACTOR AND ALL AFFECTED SUB-CONTRACTORS. THE FINAL INSTALLATION SHALL NOT COMPROMISE ANY OF THE "BASIS OF DESIGN" PERFORMANCE CHARACTERISTICS NOR SHALL IT ENCUMBER ANY OF THE DESIGN LAYOUT LOGISTICAL NECESSITIES.
- THE FINAL INSTALLATION SHALL ALSO COMPLY WITH ALL APPLICABLE BUILDING CODES. REGULATIONS. VA REQUIREMENTS PLUS ALLOW THE EQUIPMENT AND/OR MATERIALS TO FUNCTION PROPERLY AND SAFELY.
- ALL MATERIALS OR EQUIPMENT EQUIVALENT SUBSTITUTIONS SHALL BE PROVIDED ON A CONTRACTOR PREPARED ITEMIZED LISTING PER SUBSTITUTION WITH A FULL AND DETAILED DESCRIPTION OF ALL SPECIFICATIONS AND KNOWN DEVIATIONS FROM THE ORIGINAL BOD.
- THE PRIME/GENERAL CONTRACTOR SHALL NOTIFY AND COORDINATE WITH THE COR AT THE BEGINNING OF THE PROJECT, ALL SUCH KNOWN DEVIATIONS AND IMPACTS FROM THE SPECIFIC BASIS OF DESIGN SPECIFICATIONS BEFORE STARTING THE PROJECT AND/OR THE SHOP DRAWING SUBMITTALS.
- 7. IF ANY UNKNOWN DEVIATIONS FROM THE BOD REQUIREMENTS SURFACE DURING THE CONSTRUCTION PHASE, NOTIFY THE COR IMMEDIATELY AND IDENTIFY ALL IMPACTS FOR THE COR'S EVALUATION AND POSSIBLE AUTHORIZATION.




ABBREVIATIONS

ACT	ACOUSTICAL CEILING TILE	E	EAST	LAM	LAMINATE	R	RADIUS
ADJ	ADJACENT	EA	EACH	LAV	LAVATORY	RB	RESILIENT BASE
AFF	ABOVE FINISHED FLOOR	EJ	EXPANSION JOINT	LED	LIGHT EMITTING DIODE	RCP	REFLECTED CEILING PLAN
AHU	AIR HANDLING UNIT	EL	ELEVATION	LF	LINEAR FEET (FOOT)	REC	RECESSED
ALT	ALTERNATE	ELEC	ELECTRIC			RECPT	RECEPTACLE
		ELEV	ELEVATOR	LL	LEAD LINED	REINF	REINFORCED
ALUM	ALUMINUM	ENCL	ENCLOSURE	LT	LIGHT		
AMT	AMOUNT					REQD	REQUIRED
APPROX	APPROXIMATE	EQ	EQUAL	MATL	MATERIAL	RM	ROOM
AUTO	AUTOMATIC	EQUIP	EQUIPMENT	MAX	MAXIMUM	RO	ROUGH OPENING
AUX	AUXILIARY	EWC	ELECTRIC WATER COOLER	MECH	MECHANICAL		
AV	AUDIO VISUAL	EXH	EXHAUST	MFR	MANUFACTURER	S	SOUTH
AVG	AVERAGE	EXIST	EXISTING	MIN	MINIMUM	SAN	SANITARY
		EXP	EXPOSED	MISC	MISCELLANEOUS	SCHED	SCHEDULE
BAT	BATTEN	EXT	EXTERIOR	MLWK	MILLWORK	SF	SQUARE FOOT (FEET)
BD	BOARD			MO	MASONRY OPENING	SHT	SHEET
BLDG	BUILDING	FA	FIRE ALARM	MR	MOISTURE RESISTANT	SIM	SIMILAR
BLK	BLOCKING	FD	FLOOR DRAIN	MTD	MOUNTED	SPEC	SPECIFICATION
BM	BEAM	FDN	FOUNDATION	MTG	MOUNTING	SPKLR	SPRINKLER
BO	BY OWNER	FE	FIRE EXTINGUISHER			SPKR	SPEAKER
БО	DI OWINER	FEC	FIRE EXTINGUISHER CABINET	MTL	METAL	SQ	SQUARE
CEM	CEMENT	FF&E	FURNITURE, FIXTURE, AND EQUIPMENT	N.I.	NODILI		
CEM	CEMENT	FHC	FIRE HOSE CABINET	N ,	NORTH	SS	STAINLESS STEEL
CJ	CONTROL JOINT			N/A	NOT APPLICABLE	STD	STANDARD
CL	CENTER LINE	FIG	FIGURE	NAT	NATURAL	STOR	STORAGE
CLG	CEILING	FIN	FINISH	NIC	NOT IN CONTRACT	SUSP	SUSPEND
CLR	CLEAR	FIXT	FIXTURE	NO	NUMBER	SV	SHEET VINYL
CMU	CONCRETE MASONRY UNIT	FL	FLOOR	NTS	NOT TO SCALE		
COL	COLUMN	FO 	FACE OF			T&G	TONGUE AND GROOVE
CONC	CONCRETE	FP	FIRE PROTECTION OR FIREPROOF	OA	OVERALL	TEMP	TEMPERED
CONT	CONTINUOUS	FT	FOOT	OC	ON CENTER	TERR	TERRAZZO
COORD	COORDINATE	FTG	FOOTING	OH	OPPOSITE HAND	THK	THICK
CORR	CORRIDOR			OPNG	OPENING	TO	TOP OF
CPT	CARPET	GC	GENERAL CONTRACTOR	OPT	OPTIONAL	TSTAT	THERMOSTAT
CT	CERAMIC TILE	GL	GLASS	OFI	OFTIONAL	TYP	TYPICAL
CTR	CENTER	GYP BD	GYPSUM BOARD	DAT	DATTEDNI		111 10/1L
CTRL	CONTROL			PAT	PATTERN	UNO	UNLESS NOTED OTHERWISE
CINL	CONTROL	HAZ MAT	HAZARDOUS MATERIALS	PL	PLATE	ONO	ONLESS NOTED OTHERWISE
DAT	DATUM	HDW	HARDWARE	PLAM	PLASTIC LAMINATE	\/A D	VADIEC
DAT	DATUM	HM	HOLLOW METAL	PLAS	PLASTER OR PLASTIC	VAR	VARIES
DBL	DOUBLE	HT	HEIGHT	PR	PAIR	VCT	VINYL COMPOSITION TILE
DEG	DEGREE	ПІ	ПЕІВПІ	PRE	PREFINISHED	VENT	VENTILATION
DEMO	DEMOLITION	INIOI	MOLLIDED	PREP	PREPARATION	VIF	VERIFY IN FIELD
DEPT	DEPARTMENT	INCL	INCLUDED	PROVIDE	FURNISH AND INSTALL	VOL	VOLUME
DF	DRINKING FOUNTAIN	INSUL	INSULATION	PT	PAINT	VWC	VINYL WALL COVERING
DIA	DIAMETER	INT	INTERIOR	PTME	PAINT TO MATCH EXISTING		
DIFF	DIFFUSER			PTN	PARTITION	W	WEST
DIM	DIMENSION	JAN	JANITOR	PWR	POWER	W/	WITH
DN	DOWN	JST	JOIST			W/O	WITHOUT
DR	DOOR	JT	JOINT	QT	QUARRY TILE	WC	WALL COVERING
DTL	DETAIL	J-BOX	JUNCTION BOX	QTR	QUARTER	WD	WOOD
DWG	DRAWING			QTY	QUANTITY	WDW	WINDOW
- · · · -	# *** · · · · =			VΙΙ	QUANTITI	WWF	WELDED WIRE FABRIC
						** **!	TILLDED WINE LADING


MOUNTING DIMENSIONS (NOTE: THIS IS A "UNIVERSAL SHEET", ITEMS SHOWN MAY NOT ALL BE APPLICABLE TO THIS PROJECT)


- MOUNTING DIMENSIONS SHOW ACCESSIBLE AND NON-ACCESSIBLE CONDITIONS. WHEN ONLY ONE OPTION IS SHOWN ALL ITEMS IN PROJECT SHALL BE ACCESSIBLE WHEN ITEMS CAN BE ACCESSIBLE OR NON ACCESSIBLE DRAWINGS SHALL INDICATE LOCATION OF ACCESSIBLE ITEMS BY THIS SYMBOL: 🚯
- COORDINATE ITEMS SHOWN ON THIS DRAWING WITH PLANS AND SPECIFICATIONS FOR ACTUAL ITEMS USED ON THIS PROJECT. EVERY ITEM SHOWN ON THIS DRAWING MAY NOT BE USED ON THIS PROJECT.





IDIQ NO. VA69D-13-D-0042


							CONTRAC	CT NO. VA69D-14-J-3280
<u>-</u>	-	SITE PLAN:	ENGINEERS + CONSULTANTS:	NGINEERS + CONSULTANTS: ARCHITECT + ENGINEERS:		Project Title INTERIOR ARCHITECTURAL	Project Number #537-13-122	Office of
- - -	-	POLK STREET WE W		\sim	GENERAL NOTES, SYMBOLS, AND ABBREVIATIONS	CONSTRUCTION AT BUILDIN	11	Construction and Facilities Management
-	-	BUILDING 5		700 Nicholas Blvd. Suite 40 Elk Grove Village, IL 6000 T: 847.952.9362 F: 847.952.940	Approved: Project Director	Location CHICAGO, IL	Drawing Number	
ISSUED FOR SOLICITATION ISSUED FOR BIDS Revisions:	08/04/2016 12/03/2015 Date	NORTH NORTH		BANCROFT ARCHITECTS + ENGINEERS www.bancroft-ae.com Bancroft-AE Project No. 13-105-0		DateCheckedDrawn12/03/2015EMCM	G-001	Department of Veterans Affair




















STRUCTURAL GENERAL NOTES BUILDING CODE IBC 2015 RISK CATEGORY II <u>STRUCTURAL LOADING DATA — TENANT STRUCTURAL IMPROVEMENTS</u> SLAB ON GRADE 100 PSF CONCENTRATED LOAD 1,000 LBS HANDRAIL AND GUARDRAIL SYSTEM CONCENTRATED LOAD 200 LBS ANY DIRECTION ANY HANDRAIL AND GUARDRAIL SYSTEM UNIFORM LOAD OF 50 LB/FT ANY DIRECTION 1.0 GENERAL 1.1 THE CONTRACTOR SHALL VERIFY IN THE FIELD ALL EXISTING CONDITIONS INCLUDING ALL DIMENSIONS AND ELEVATIONS. THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE COR OF ANY DISCREPANCIES BETWEEN THE EXISTING CONDITIONS AND THE DESIGN DOCUMENTS. 1.2 THE STRUCTURAL DRAWINGS ARE TO BE USED IN CONJUNCTION WITH THE ARCHITECTURAL, MECHANICAL AND ELECTRICAL DRAWINGS. 1.3 THE CONTRACTOR SHALL COORDINATE WITH THE MECHANICAL AND ARCHITECTURAL DRAWINGS AND WITH THE MECHANICAL CONTRACTOR, 1.4 THE CONTRACTOR SHALL NOTIFY THE COR IMMEDIATELY OF ANY DISCREPANCIES. 1.5 THE CONTRACTOR SHALL COORDINATE THE WORK OF ALL TRADES AND MAKE NECESSARY INVESTIGATIONS AND FIELD MEASUREMENTS. 1.6 DO NOT SCALE DRAWINGS. 1.7 THE A/E HAS NO SUPERVISORY RESPONSIBILITY, HAS NO CONTROL OF OR RESPONSIBILITY FOR THE MEANS, METHODS, TECHNIQUES, PROCEDURES OR SEQUENCE OF CONSTRUCTION, HAS NO RESPONSIBILITY FOR THE FAILURE OF ANY CONTRACTOR TO PERFORM THE WORK IN ACCORDANCE WITH THE DESIGN DOCUMENTS AND NO RESPONSIBILITY TO DEVISE, IMPLEMENT OR ENFORCE ANY SAFETY PRECAUTIONS OR PROGRAMS FOR THE PROJECT 2.0 EXCAVATION 2.1 CONTRACTOR SHALL LOCATE ALL EXISTING BELOW GRADE UTILITIES AND INTERFERENCES PRIOR TO START OF WORK. NOTIFY THE COR OF ANY INTERFERENCES. 2.2 REMOVE EXISTING PAVING AND SIDEWALKS IN AREA OF NEW RAMP 2.3 STRIP TOPSOIL OVER THE ENTIRE RAMP AREA. 2.4 EXCAVATE AS REQUIRED FOR FOUNDING OF TRENCH FOOTINGS ON UNDISTURBED SOIL OR COMPACTED ENGINEERED FILL OF 3,000 PSF NET BEARING CAPACITY. 2.5 FOOTINGS SHALL BEAR AT SUFFICIENT DEPTH TO PROVIDE ADEQUATE FROST COVERAGE PER LOCAL REQUIREMENTS. IN NO CASE SHALL DEPTHS BE LESS THAN THE MINIMUM DEPTHS SHOWN ON PLANS AND DETAILS. 2.6 MAINTAIN ALL EXCAVATIONS FREE OF WATER CONTINUOUSLY. BACKFILL BEHIND EXTERIOR WALLS ON THE OUTSIDE OF THE BUILDING WITH COMPACTED GRANULAR FILL PLACED IN 10" LOOSE LIFTS COMPACTED TO 85% OF MAXIMUM DENSITY. 2.8 BACKFILL ON INSIDE OF BUILDING WITH COMPACTED GRANULAR FILL PLACED IN 10" LOOSE LIFTS COMPACTED TO 95% OF MAXIMUM DENSITY. 2.9 CONTRACTOR'S TESTING SERVICE SHALL CONFIRM THE ALLOWABLE BEARING PRESSURES AND SOIL CONDITIONS. 3.0 CONCRETE 3.1 GENERAL REQUIREMENTS ___ ALL WORK SHALL CONFORM TO ALL REQUIREMENTS OF THE FOLLOWING EXCEPT AS MODIFIED BY THE REQUIREMENTS OF THE CONTRACT DOCUMENTS. ACI 301-10, SPECIFICATION FOR STRUCTURAL CONCRETE ACI 318-11 BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE ACI 360-10 GUIDE FOR DESIGN OF SLAB ON GRADES ACI 315 ACI DETAILING MANUAL ACI 305-10 GUIDE TO HOT WEATHER CONCRETING ACI 306-05 GUIDE TO COLD WEATHER CONCRETING $\overline{}$ 3.2 SUBMITTALS CONCRETE MIXES WITH HISTORICAL TEST DATA. MATERIAL CERTIFICATES: CEMENT, AGGREGATES, ADMIXTURES, REINFORCING STEEL REINFORCING STEEL PLACEMENT DRAWINGS 3.3 PRODUCTS REINFORCING BARS: ASTM A615 GRADE 60 REINFORCING BARS WELDABLE: ASTM A706 GRADE 60 PLAIN WIRE FABRIC: ASTM A185 PORTLAND CEMENT: ASTM C150 TYPE I OR II. AGGREGATES: ASTM C33 WATER: POTABLE ASTM C94 ADMIXTURES AIR ENTRAINING ASTM C260 CHEMICAL ADMIXTURES ASTM C 494 AIR CONTENT FOR CONCRETE EXPOSED TO WEATHER: 4 TO 7%. CONCRETE STRENGTH: F'C 4,000 PSI AT 28 DAYS MIXING PER ASTM C94 CURING COMPOUNDS: ASTM C309 OR C1315 3.4 EXECUTION CONCRETE CAST AGAINST AND PERMANENTLY EXPOSED TO EARTH 3" CONCRETE EXPOSED TO EARTH OR WEATHER 2" CONCRETE NOT EXPOSED TO WEATHER 1-1/2" ALL FOOTINGS AND WALL FOOTINGS SHALL BE FORMED UNLESS NOTED. LAP SPLICE LENGTHS PER ACI 318 CHAPTER 12 USING A CLASS B SPLICE. ALL WELDED WIRE FABRIC SHALL BE LAPPED ONE GRID MINIMUM ALL SLAB-ON-GRADE CONSTRUCTION JOINTS SHALL BE KEYED; REINFORCING SHALL NOT PASS THROUGH; 24 HOURS MINIMUM BETWEEN ADJACENT POURS. LOCATE JOINTS AS SHOWN ON PLANS; WHERE NOT SHOWN, CONTROL OR CONSTRUCTION JOINTS SHALL BE PLACED IN ACCORDANCE WITH ACI RECOMMENDATIONS I.E., A MAXIMUM PANEL SIZE (IN FEET) EQUAL TO APPROXIMATELY THREE TIMES THE THICKNESS OF THE SLAB (IN INCHES) IN BOTH DIRECTIONS. HOOK ENDS OF BARS INTERRUPTED BY OPENINGS. HOOK TOP BARS AT ALL EDGES. AT ALL WALL AND SLAB OPENINGS, PROVIDE 2-#5 BARS X OPENING WIDTH PLUS 4 FEET (2 FEET EACH SIDE) EACH FACE, UNLESS SHOWN OTHERWISE. PLACEMENT OF CONCRETE IN COLD WEATHER SHALL COMPLY WITH ACI306 PLACEMENT OF CONCRETE IN HOT WEATHER SHALL COMPLY WITH ACI305 TOLERANCES SHALL MEET ACI 117, ACI 301 AND ACI 318 AS A MINIMUM. SLAB ON GRADE FINISH: BROOM

4.0 STRUCTURAL STEEL 4.1 GENERAL ALL STRUCTURAL STEEL WORK SHALL CONFORM TO THE AISC "SPECIFICATIONS FOR STRUCTURAL STEEL BUILDINGS" 2005, "SPECIFICATION FOR STRUCTURAL JOINTS USING ASTM A325 OR A490 BOLTS" 2004, "CODE OF STANDARD PRACTICE FOR STEEL BUILDINGS AND BRIDGES," 2005 AND AWS D1.1 2004. THE PROVISIONS OF THE ALLOWABLE STRENGTH DESIGN METHOD (ASD) WAS USED AS A BASIS FOR DESIGN. ALL FORCES/REACTIONS INDICATED ON THE DESIGN DOCUMENTS ARE THEREFORE NON-FACTORED ASD FORCES/REACTIONS. THE CONTRACTOR?S STRUCTURAL STEEL DETAILER SHALL PREPARE STEEL ERECTION AND SHOP DRAWINGS IN ACCORDANCE WITH THE GUIDELINES AND GOOD PRACTICES NOTED IN THE AISC "DETAILING FOR STEEL CONSTRUCTION." THIRD EDITION 4.2 SUBMITTALS CHECKED STEEL SHOP DRAWINGS. CONNECTION CALCULATIONS PREPARED, SIGNED AND SEALED BY CONTRACTOR'S LICENSED STRUCTURAL ENGINEER. MATERIAL CERTIFICATES (UPON REQUEST) WELDING CERTIFICATES (UPON REQUEST) STAIR/HANDRAIL/GUARDRAIL STRUCTURAL CALCULATIONS PREPARED, SIGNED AND SEALED BY CONTRACTOR'S LICENSED STRUCTURAL ENGINEER. 4.3 MATERIALS ALL STRUCTURAL STEEL SHAPES SHALL BE ASTM A992 (Fy=50 ksi) ALL STRUCTURAL STEEL PLATES AND ANGLES SHALL BE ASTM A36 (Fy=36 KSI). ALL STRUCTURAL TUBES SHALL BE ASTM A500 GRADE B (Fy=46 KSI). ALL STRUCTURAL PIPES SHALL BE ASTM A53 GRADE B (Fy=35 KSI). ALL WELDING SHALL CONFORM TO AMERICAN WELDING SOCIETY "STRUCTURAL WELDING CODE", AWS D1.1. ALL WELD ELECTRODES SHALL BE E70XX AND ALL WELDING SHALL BE PERFORMED BY CERTIFIED WELDERS. ALL WELDING TO CLEAN BARE STEEL. ALL WELD SIZES SHOWN ARE SIZED FOR LOAD ONLY. WELDS SHALL BE INCREASED IN SIZE AS REQUIRED TO MEET AISC MINIMUMS. ALL GROOVE WELDS SHOWN ARE FULL PENETRATION WELDS UNLESS NOTED OTHERWISE. WELDS NOTED AS PARTIAL PENETRATION GROOVE WELDS SHOW "EFFECTIVE" SIZE OF WELD. WELD JOINTS SHALL BE DETAILED BASED ON PROCESS USED AND POSITION OF WELD TO MEET THE "EFFECTIVE" SIZE SHOWN ON THE DRAWINGS. ALL BOLTING SHALL BE WITH 3/4" DIAMETER A325 (BEARING TYPE) HIGH STRENGTH BOLTS UNLESS NOTED OTHERWISE. ALL CONNECTIONS SHALL CONFORM TO AISC "MANUAL OF STEEL CONSTRUCTION", 13TH ED., TABLE 10-1. MINIMUM CONNECTION CAPACITY SHALL BE 50% OF THE TOTAL UNIFORM LOAD CAPACITY NON COMPOSITE BEAMS AND 75% OF THE TOTAL UNIFORM LOAD CAPACITY FOR COMPOSITE BEAMS AS SHOWN IN TABLES OF "UNIFORM LOAD" CONSTANTS" IN PART 3 OF THE MANUAL. UNLESS LARGER REACTIONS ARE SHOWN ON THE PROVIDE FULL SIZE 1/4" SETTING PLATES ON 4,000 PSI NON-SHRINK GROUT FOR ALL COLUMNS AND (4)-3/4" DIAMETER ASTM F-1554-36 ANCHOR BOLTS, UNLESS NOTED ERECT ALL MEMBERS WITH NATURAL CAMBER UP, EXCEPT FOR CERTAIN CANTILEVERED PROVIDE SUB-FRAMING FOR EQUIPMENT SUPPORTED ON OR SUSPENDED FROM THE STRUCTURE. ALL STEEL SHALL BE SHOP COATED WITH PRIME PAINT AS SPECIFIED. MASK SURFACES TO BE FIELD WELDED AND AT BOLT HOLES IN FAYING SURFACES OF SLIP CRITICAL BOLTED 4.4 EXECUTION VERIFY THAT FIELD CONDITIONS ARE ACCEPTABLE AND ARE READY TO RECEIVE WORK. STEEL ERECTION TOLERANCES SHALL BE IN ACCORDANCE WITH THE CODE OF STANDARD PRACTICE. 5.0 GALLERY WORK 5.1 ALL GALLERY WORK (GUARDRAILS/HANDRAIL) ARE DELEGATED DESIGN ITEMS AND SHALL MEET THE DESIGN REQUIREMENTS OF THE BUILDING CODE NOTED ABOVE. OSHA AND ASCE 7 SECTION 4. 5.2 GUARDRAIL/HANDRAIL SHALL BE DESIGNED TO MEET CODES LISTED ABOVE. POSTS AND RAILS SHALL BE A MINIMUM 1-1/2" DIAMETER STANDARD GALVANIZED PIPE (ASTM A53 GR B) WITH ALL WELDED JOINTS AND FIELDED WELDED TO EMBED PLATES. POSTS SHALL BE SPACED NO GREATER THAN 4'-0" ON CENTER. SHOP FABRICATE IN AS LARGE OF SECTIONS AS POSSIBLE FOR EASE OF ERECTION. ALL EDGES SHALL BE ROUNDED AND WELDS GROUND SMOOTH. 5.3 TOUCH UP FIELD GALVANIZING AT ALL WELDS. 5.4 PROVIDE WEEP HOLES AT BASE OF ALL POSTS. 6.0 SHOP DRAWINGS AND TEST REPORTS

- 6.1 GENERAL CONTRACTOR SHALL CHECK ALL SHOP DRAWINGS BEFORE SUBMITTAL TO
- COR FOR REVIEW. 6.2 REVIEW BY COR WILL BE FOR CONFORMANCE TO GENERAL LAYOUT AND DESIGN INTENT ONLY. CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR ACCURACY OF DIMENSIONS, FABRICATION, FIT UP OF PARTS AND BILLS OF MATERIALS. CONTRACTOR SHALL COORDINATE WORK OF VARIOUS TRADES AND MAKE NECESSARY FIELD MEASUREMENTS.
- 6.3 THE CONTRACT SPECIFICATIONS PROVIDE A COMPLETE LISTING OF SUBMITTALS. THE FOLLOWING IS A SUMMARY OF THE REQUIRED SUBMITTALS:

CONCRETE PRODUCT DATA SHEETS

PROPOSED CONCRETE MIX DESIGNS WITH ASSOCIATED HISTORICAL TEST DATA.

MATERIAL CERTIFICATIONS

REINFORCING STEEL PLACEMENT DRAWINGS PER ACI 315 FIELD QUALITY CONTROL TESTS: SLUMP, AIR CONTENT, COMPRESSIVE STRENGTH ETC.

GALLERY WORK (STAIRS/HANDRAIL/GUARD RAIL/LADDERS ETC) PRODUCT DATA SHEETS

MATERIAL CERTIFICATIONS

STRUCTURAL STEEL SHOP DRAWINGS

DESIGN CALCULATIONS SIGNED AND SEALED BY PROFESSIONAL ENGINEER.

7.0 <u>DESIGN DELEGATION</u>

- 7.1 CERTAIN COMPONENTS OF THE COMPLETED CONSTRUCTION ARE BEING DESIGN DELEGATED TO THE MANUFACTURER OF THE COMPONENT. THE FOLLOWING ARE DESIGNATED TO BE DESIGN DELEGATED ON THIS PROJECT GUARDRAIL, HANDRAIL, ETC.
- OTHER WORK AS LISTED ON DRAWINGS, SPECIFICATIONS AND CUSTOMARY INDUSTRY STANDARDS 7.2 WHERE DELEGATION OF DESIGN IS SPECIFIED, THE MANUFACTURER SHALL BE RESPONSIBLE FOR RETAINING THE SERVICES OF A LICENSED STRUCTURAL ENGINEER IN THE STATE HAVING JURISDICTION. IS LOCATED. THE LICENSED STRUCTURAL ENGINEER SHALL DESIGN AND DETAIL COMPONENTS TO MEET GOVERNING BUILDING CODES, STANDARDS AND THE SPECIFIED PERFORMANCE CRITERIA. SIGNED AND SEALED CALCULATIONS SHALL BE SUBMITTED FOR RECORD. THE DESIGN DELEGATED STRUCTURAL ENGINEER SHALL BE SOLELY RESPONSIBLE FOR THE DESIGN OF THE COMPONENT.

8.0 <u>DEMOLITION</u>

- 8.1 THE CONTRACTOR SHALL CAREFULLY REMOVE ONLY THE EXISTING ITEMS IDENTIFIED ON THE ARCHITECTURAL AND STRUCTURAL DRAWINGS. IN NO CASE SHALL THE REMOVAL OF ANY PORTION OF THE EXISTING STRUCTURE BE PERFORMED IN SUCH A WAY AS TO AFFECT THE STRUCTURAL INTEGRITY OF THE REMAINING PORTION OF THE BUILDING. THE CONTRACTOR SHALL NOTIFY THE COR IMMEDIATELY OF ANY STRUCTURAL ITEMS WHICH NEED TO BE DEMOLISHED BUT ARE NOT CLEARLY IDENTIFIED ON THE STRUCTURAL OR ARCHITECTURAL DRAWINGS. THE CONTRACTOR SHALL MINIMIZE THE EXTENT OF THE DEMOLITION TO THE EXISTING STRUCTURE TO ONLY THAT REQUIRED TO INSTALL THE NEW BUILDING ADDITION.
- STRUCTURAL TESTS AND INSPECTIONS (IBC 2015)
- 9.1 ALL TESTS AND INSPECTIONS SHALL BE PERFORMED BY AN INDEPENDENT TESTING AND INSPECTION AGENCY IN ACCORDANCE WITH CHAPTER 17 OF IBC 2015. THE SPECIAL INSPECTOR SHALL OBSERVE THE WORK ASSIGNED FOR CONFORMANCE TO THE APPROVED DESIGN DRAWINGS AND SPECIFICATIONS.
- 9.2 THE SPECIAL INSPECTOR SHALL FURNISH INSPECTION REPORTS TO COR AND THE GENERAL CONTRACTOR. ALL DISCREPANCIES SHALL BE IMMEDIATELY BROUGHT TO THE ATTENTION OF THE COR FOR CORRECTION. IF UNCORRECTED, THE SPECIAL INSPECTOR SHALL NOTIFY THE COR AND THE GENERAL CONTRACTOR.
- 9.3 THE SPECIAL INSPECTOR SHALL SUBMIT A FINAL REPORT STATING WHETHER THE WORK REQUIRING SPECIAL INSPECTION WAS IN CONFORMANCE WITH THE APPROVED PLANS AND SPECIFICATIONS AND THE APPLICABLE WORKMANSHIP PROVISIONS OF THIS CODE
- 9.4 JOB SITE VISITS BY THE A/E OF RECORD DOES NOT CONSTITUTE AN OFFICIAL SPECIAL INSPECTION.
- 9.5 THE FOLLOWING LIST OF MATERIALS AND WORK REQUIRE SPECIAL INSPECTIONS ALLOWABLE SOIL BEARING PRESSURE

PROOF ROLLING OF GRADE BELOW SLAB ON GRADE CONCRETE REBAR PLACEMENT CONCRETE PLACEMENT

GUARDRAIL/HANDRAIL PLACEMENT

THE CONTRACTOR SHALL PROVIDE AN INDEPENDENT, 3RD PARTY, TESTING LABORATORY AND INSPECTION AGENCY TO PROVIDE ALL REQUIRED INSPECTIONS AND TESTING AS PER THE PROJECT REQUIREMENTS AND THE SPECIFICATIONS, SUBJECT TO COR APPROVAL(S).

IDIQ NO. VA69D-13-D-0042

-	SITE PLAN:	ENGINEERS + CONSULTANTS: ARCHITECT + ENGINEERS:			Drawing Title STRUCTURAL GENERAL NOTES	Project Title INTERIOR ARCHITECTURAL	Project Number #537-13-122	Office of
- - -	POLK STREET		\sim			CONSTRUCTION AT BUILDING 5	Building Number 5	Construction and Facilities
-	BUILDING 5	JWALogo_Ad_HighRes.jpg	- 13ana(/X	700 Nicholas Blvd. Suite 403 Elk Grove Village, IL 60007 T: 847.952.9362 F: 847.952.9403	Approved: Project Director	Location CHICAGO, IL	Drawing Number	Management
ISSUED FOR SOLICITATION ISSUED FOR BIDS Revisions:	08/04/2016 12/03/2015 Date		BANCROFT ARCHITECTS + ENGINEERS	www.bancroft-ae.com Bancroft-AE Project No. 13-105-08		Date Checked Drawn 12/03/2015	Drawn S-103	Department of Veterans Affairs

ELECTRICAL GENERAL NOTES: ELECTRICAL SYMBOL LIST: DESCRIPTION THE FOLLOWING ARE THE SOLE PROPRIETARY VENDORS SYMBOL DESCRIPTION 7. ALL WIRE AND CABLE SHALL BE COPPER ONLY, TYPE "THWN" OR "XHHW". ELECTRICAL CONTRACTOR SHALL REVIEW ENTIRE SET OF CONTRACT DOCUMENTS: CHOSEN BY THE VA FOR THE BELOW ITEMS: INCLUDING BUT NOT NECESSARILY LIMITED TO ALL ARCHITECTURAL. ALL MINIMUM WIRE SIZE TO BE #12 EXCEPT FOR CONTROL WIRE. ALL WIRE SIZE 2-DATA PORTS MOUNTED HORIZONTALLY AT +18" A.F.F. UNLESS A.F.F. ABOVE FINISHED FLOOR STRUCTURAL, ALL MECHANICAL, ALL ELECTRICAL, ALL PLUMBING, AND ENTIRE #10 AWG AND SMALLER SHALL BE SOLID. ALL CABLE #8 AWG AND LARGER OTHERWISE NOTED PROJECT MANUAL. ELECTRICAL CONTRACTOR SHALL ACKNOWLEDGE AND INCLUDE SHALL BE STRANDED. FOR ALL UNDERGROUND SERVICE CONDUCTORS FROM ELECTRICAL CONTRACTOR THE UTILITY COMPANY TRANSFORMER TO THE SERVICE EQUIPMENT SHALL 2 DATA OUTLETS AND 2 VOICE OUTLETS MOUNTED HORIZONTALLY IN THE SCOPE OF WORK (CONTRACT) ALL CONDITIONS PERTINENT TO THE COMPLETION OF THE ELECTRICAL WORK. ELECTRICAL CONTRACTOR SHALL FULLY BE TYPE "RHH-RHW-USE" (CROSS-LINKED POLYETHYLENE INSULATION). INDICATES FIXTURE CONNECTED TO EMERGENCY SERVICE AT +18" A.F.F. UNLESS OTHERWISE NOTED CARD READER/ACCESS COORDINATE ELECTRICAL WORK WITH THE INSTALLATION OF WORK BY ALL OTHER 1 VOICE OUTLET AND 1 DATA OUTLET MOUNTED HORIZONTALLY AT | ELECTRIC WATER COOLER TRADES AND MAKE NECESSARY FIELD ADJUSTMENTS AS REQUIRED TO VIDEO SURVEILLANCE 18. ALL 20 AMPERE BRANCH CIRCUIT HOMERUNS 100' OR LONGER SHALL BE ACCOMMODATE THE ELECTRICAL INSTALLATION. ALL OF THE ABOVE SHALL BE 18" A.F.F. UNLESS NOTED OTHERWISE MINIMUM #10 AWG OR LARGER SIZED TO LIMIT VOLTAGE DROP. COMPLY WITH GROUND FAULT INTERRUPTER INCLUDED IN THE SCOPE OF WORK AT NO ADDITIONAL COST TO THE VA. FIRE ALARM SYSTEMS ALL CODES, REGULATIONS, PROJECT AND VA REQUIREMENTS. SINGLE GANG VOICE OUTLET, MOUNTED VERTICALLY 48" A.F.F. STUB CONDUIT 6" INTO ACCESSIBLE CEILING . ELECTRICAL CONTRACTOR SHALL CAREFULLY EXAMINE THE DRAWINGS AND GROUND INDICATES GREEN GROUND CONDUCTOR CONNECTED BUILDING AUTOMATION 19. NO ROMEX OR BX WILL BE PERMITTED. SPACE UNLESS NOTED OTHERWISE TO EQUIPMENT AND PANEL SPECIFICATIONS, VISIT THE SITE OF THE WORK, AND FULLY INFORM HIM/HER SELF AS TO ALL CONDITIONS AND MATTERS THAT CAN, IN ANY WAY, AFFECT 20. ALL WIRE SHALL BE INSTALLED IN THIN WALL (E.M.T.) CONDUIT UNLESS NIGHT LIGHT, 24 HOUR OPERATION FIRE ALARM-MANUAL PULL STATION, 48" A.F.F. THE WORK OR THE COST THEREOF, SHOULD THIS CONTRACTOR FIND OTHERWISE NOTED. MINIMUM SIZE SHALL BE 3/4" EXCEPT FOR DROPS FOR DISCREPANCIES IN, OR OMISSIONS FROM, THE DRAWINGS, SPECIFICATIONS OR DEVICES, SWITCH LEGS, TEMPERATURE CONTROL CONDUITS, WHERE U.N.O. UNLESS NOTED OTHERWISE OTHER DOCUMENTS OR BE IN DOUBT AS TO THEIR MEANING, NOTIFY THE COR INDICATED OR AS CALLED FOR ON DRAWINGS. AT ONCE, IN WRITING, OF ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS WEATHERPROOF AND NEW WORK, OR BETWEEN ELECTRICAL WORK AND THE WORK OF OTHER FIRE ALARM- STROBE ONLY DEVICE 21. ALL THINWALL FITTINGS SHALL BE OF THE STEEL COMPRESSION GLAND TYPE. TRADES AND OBTAIN CLARIFICATION PRIOR TO SUBMITTING ANY BID. LACK OF SINGLE POLE TOGGLE SWITCH, 20 AMPERE RATED, MOUNTED 48" SUCH NOTIFICATION SHALL BE CONSTRUED TO INDICATE NO DISCREPANCIES OR 22. ALL UNDERFLOOR, UNDERGROUND OR EXPOSED—TO—WEATHER CONDUIT SHALL FIRE ALARM - MAGNETIC HOLD OPENS A.F.F. UNLESS NOTED OTHERWISE. CONFLICTS EXIST. ADDITIONAL COMPENSATION WILL NOT BE GRANTED AFTER BE HEAVYWALL GALVANIZED RIGID STEEL. (G.R.S.), MINIMUM 3/4". SUBSCRIPT: "a" — LOWER CASE LETTER INDICATES SWITCH AWARD OF CONTRACT FOR ANY WORK REQUIRED TO COMPLY WITH THESE (SD) | FIRE ALARM - CEILING MOUNTED SMOKE DETECTOR CONTROL REQUIREMENTS. 23. ALL CONDUITS 2" OR LARGER SHALL BE GALVANIZED RIGID STEEL OR "3" - DENOTES THREE WAY TOGGLE SWITCH INTERMEDIATE METAL CONDUIT (I.M.C.). FIRE ALARM — CEILING MOUNTED HEAT DETECTOR THE ELECTRICAL CONTRACTOR IS RESPONSIBLE TO FURNISH AND INSTALL A "2P" - DENOTES TWO POLE TOGGLE SWITCH COMPLETE ELECTRICAL SYSTEM. WHERE THERE IS NO MENTION OF THE 24. ELECTRICAL CONTRACTOR SHALL INSTALL SIZE OF CONDUIT SHOWN AND AS CLOSED CIRCUIT TELEVISION OUTLET - CEILING MOUNTED RESPONSIBLE PARTY FOR A SPECIFIC ITEM TO BE FURNISHED, INSTALLED OR ψ^{OC} | WALL MOUNTED DUAL-TECHNOLOGY (PIR/ULTRASONIC) OCCUPANCY SCHEDULED ABOVE AND SHALL NOT REDUCE SIZING OF CONDUITS TO SUIT UNLESS OTHERWISE NOTED. WIRED ON THE ELECTRICAL DRAWINGS, THE ELECTRICAL CONTRACTOR WILL SENSOR, 48" A.F.F. UNLESS NOTED OTHERWISE. WIRE FILL CAPACITY. BE RESPONSIBLE COMPLETELY FOR ALL PURCHASES AND LABOR FOR A COMPLETE OPERATING SYSTEM FOR THIS ITEM. 25. ALL CONDUIT FASTENERS, STRAPS, SUPPORTS ETC. MUST BE "BOLT-ON" THERMAL OVERLOAD TOGGLE SWITCH WITH PROPERLY AUDIO/VISUAL GALVANIZED STEEL ON EXPOSED CONSTRUCTION AND IN WET AREAS. . ANY MENTION OF A SPECIFIC VOLTAGE ON THE ELECTRICAL DRAWINGS SHALL SIZED HEATER ELEMENTS, 48" A.F.F. UNLESS EQUIPMENT MOUNTED SNAP-ON BLACK METAL "CADDY" CLIPS IN METAL PARTITION WALLS AND NOT RELIEVE THE ELECTRICAL CONTRACTOR OF THE RESPONSIBILITY TO VERIFY ABOVE SUSPENDED CEILINGS WILL BE PERMITTED. ALL FASTENERS, THE VOLTAGE PRIOR TO PURCHASING OR ROUGH-IN WORK. SINGLE POLE SLIDE TYPE ARCHITECTURAL INCANDESCENT STRAPS, CLIPS, ETC. SHALL BE UL LISTED FOR THEIR USE. DIMMER SWITCH WITH FINS, 1200 WATT CAPACITY. SINGLE SIDED EXIT SIGN SCHEDULE . ELECTRICAL CONTRACTOR SHALL VERIFY ALL OUTLET MOUNTING ARRANGEMENTS. IALL NON-DIMMING SWITCHED ADJACENT TO 26. NO CONDUITS SHALL BE ROUTED THROUGH HVAC AIR DUCTS. HEIGHTS AND LOCATIONS WITH THE ARCHITECTURAL DRAWINGS PRIOR TO OR IN SAME ROOM SHALL BE THE SLIDE TYPE TO MATCH DIMMERS. ROUGH-IN. ANY MENTION OF A SPECIFIC MOUNTING ARRANGEMENT, HEIGHT OR LETTERING MANUFACTURER/MODEL CHICAGO CODE# SUBSCRIPT: "FD" — DENOTES FLUORESCENT DIMMER TO MATCH 27. ALL CONDUIT RACEWAYS SHALL BE CONCEALED IN OR WITHIN: WALLS, CEILING LOCATION SHALL NOT RELIEVE THE ELECTRICAL CONTRACTOR OF THE RESPONSIBILITY TO VERIFY THE SPECIFIC REQUIREMENT WITH THE EQUIPMENT CAVITY, ROOF CONSTRUCTION (WHERE APPROVED), SLAB, GRADE, ETC. UNLESS "LV" - DENOTES LOW VOLTAGE DIMMER TO MATCH EXIT EMERGI-LITE#SNX42-RW-TBH27 FURNISHED OR THE OTHER TRADES WORKING IN THE SAME AREA. NO ADDITIONS OTHERWISE NOTED. ANY RACEWAY THAT IS TO BE ROUTED EXPOSED SHALL BE ABOVE TO THE CONTRACT SUM WILL BE PERMITTED FOR OUTLETS IN WRONG LOCATIONS, APPROVED BY THE VA AND SUCCESSFULLY REVIEWED BY THE A/E. PRIOR TO EMERGI-LITE#SNX42-RW-TBH27 IN CONFLICT WITH OTHER WORK ETC. THE VA RESERVES THE RIGHT TO INSTALLATION. ALL CONDUIT SHALL BE ROUTED PARALLEL OR PERPENDICULAR DUPLEX RECEPTACLE, 120 VOLT, 20 AMPERE RATED, 18" A.F.F. TO WALLS AND STRUCTURAL MEMBERS WITH 90° BENDS WHERE REQUIRED AND RELOCATE ANY DEVICE 10'-0" PRIOR TO ROUGH-IN WITHOUT ANY ADDITIONAL UNLESS NOTED OTHERWISE. MTD HORIZONTALLY IN JUNCTION BOX SHALL BE RACKED. PULL AND JUNCTION BOXES SHALL BE HELD TO A CHARGES BY THE ELECTRICAL CONTRACTOR. EMERGI-LITE#SNX42-RW-TBH27 | SUBSCRIPT: "GFI" - DENOTES GROUND FAULT INTERRUPTER TYPE RECEPTACLE 6. ALL INSTRUMENTS, APPARATUS AND EQUIPMENT SHALL BE TESTED AND C12 EMERGI-LITE#SNX42-RW-TBH27 "IG" - DENOTES ISOLATED GROUND TYPE PROVED TO BE ELECTRICALLY AND MECHANICALLY WITHOUT DEFECTS. THE 28. NO WIREWAY. THROUGH OR JUNCTION SHALL BE UTILIZED WHERE MORE THAN 8 ELECTRICAL SYSTEM SHALL BE TESTED FOR GROUNDS OR SHORTS AND IF RECEPTACLE CONDUITS ARE ENTERING OR LEAVING. MULTIPLE WIREWAYS, TROUGHS OR JUNCTIONS SHALL BE UTILIZED. IN NO CASE SHALL FEEDER OR STAIRS EMERGI-LITE#SNX42-RW-TBH27 SHORTED OR GROUNDED, ALL SUCH WIRES SHALL BE REMOVED AND REPLACED. CONDUIT OR CABLING BE MIXED WITH BRANCH CONDUIT. IF TROUBLE IS WITHIN CIRCUIT, ALL METERS, CABLES, EQUIPMENT OR APPARATUS DOUBLE DUPLEX RECEPTACLE, 120V, 20 AMP RATED 18" A.F.F. NECESSARY FOR MAKING ALL TESTS SHALL BE FURNISHED AND PROVIDED BY UNLESS OTHERWISE NOTED. MOUNTED HORIZONTALLY IN COMMON EMERGI-LITE#SNX42-RW-TBH27 ELECTRICAL CONTRACTOR. 29. NO CONDUITS SHALL BE ROUTED ON ROOF. ELECTRICAL CONTRACTOR SHALL COORDINATE ROOF PENETRATIONS WITH MECHANICAL PIPE CURBS. WHERE DUPLEX RECEPTACLE, 120V, 20 AMPERE RATED 6" ABOVE EMERGI-LITE#SNX42-RW-TBH27 CONDUIT MUST BE RUN ON ROOF, IT SHALL BE RACKED WITH OTHER TRADES 7. ELECTRICAL CONTRACTOR SHALL ESTABLISH SAFE WORKING PROCEDURES FINISHED COUNTER TOP OR BACK SPLASH MOUNTED HORIZONTALLY. WHERE POSSIBLE OR PROVIDED WITH ITS OWN ROOF RACK SUPPORT SYSTEM FOR THE PROTECTION OF THE WORKMEN IN ALL PHASES OF WORK, COMPLYING AT LOCATIONS WHERE THERE IS NO COUNTER TOP, WITH PROPER ROOF PLATE SO AS NOT TO CAUSE DAMAGE TO ROOF EMERGI-LITE#SNX42-RW-TBH27 WITH THE APPLICABLE PROVISIONS OF ALL CITY, STATE, AND FEDERAL SAFETY RECEPTACLE SHALL BE MOUNTED 42" A.F.F. UNLESS NOTED COVERING. LAWS (OSHA). IN ADDITION TO MEETING THE FULL REQUIREMENTS OF THE OTHERWISE. PROJECT AND THE VA, THE ELECTRICAL CONTRACTOR SHALL EQUALLY COMPLY 30. ELECTRICAL CONTRACTOR SHALL FIREPROOF ALL CONDUIT OPENINGS WITH THE RECOMMENDATIONS CONTAINED WITHIN THE "MANUAL OF ACCIDENT CEILING MOUNTED DUPLEX RECEPTACLE, 120V, 20 AMPERE BETWEEN FLOORS AND ANY INTERSPACE FIRE SEPARATION BLOCK WALLS PREVENTION IN CONSTRUCTION" AS ISSUED BY THE ASSOCIATION OF GENERAL WITH VA APPROVED UL LISTED FIRE RETARDANT MATERIAL. AS CONTRACTORS OF AMERICA, INC., 20TH AND E. STREETS, N.W. WASHINGTON, D.C. SUCCESSFULLY REVIEWED BY THE A/E. SPECIAL PURPOSE RECEPTACLE, VOLTAGE, RATING AND MOUNTING AS NOTED ON PLANS B. THE ARCHITECT/ENGINEER(A/E) MAY MAKE PERIODIC VISITS TO THE JOB SITE TO DOUBLE SIDED EXIT SIGN SCHEDULE 1. ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL ALL SLEEVES THRU OBSERVE THE PROGRESS OF THE WORK AND TO OBSERVE WHETHER OR NOT JUNCTION BOX WALL MOUNTED WALLS AND CORING THRU FLOORS. ELECTRICAL CONTRACTOR SHALL IT IS BEING PERFORMED IN ACCORDANCE WITH THE ELECTRICAL PLANS AND WEATHERPROOF ALL PENETRATIONS THRU FOUNDATION AND EXTERIOR WALLS. LETTERING MANUFACTURER/MODEL CHICAGO CODE# SYMBOL SPECIFICATIONS. THIS DOES NOT IN ANY WAY MEAN THAT THE A/E IS A ↓ JUNCTION BOX WITH FLEXIBLE CONDUIT CONNECTION GUARANTOR OF THE CONTRACTOR'S WORK, OR RESPONSIBLE FOR SAFETY IN, 32. FINAL EQUIPMENT CONNECTION TO PILOT CONTROL DEVICES SHALL BE MADE ON, OR ABOUT THE JOB SITE, IN CONTROL OF THE SAFETY OR ADEQUACY EXIT EMERGI-LITE#SNX43-RW-TBH27 WITH 1'-0" MINIMUM LENGTH OF FLEXIBLE CONDUIT CONNECTION (IE. SOLENOID _____ MOTOR CONNECTION SAFETY OR ADEQUACY OF ANY SHIPMENT, BUILDING, SCAFFOLDING, FORMS VALVES, MOTORIZED DAMPERS, ETC.). OR OTHER WORK AIDS, OR FOR SUPERINTENDING, DIRECTING OR HAVING EMERGI-LITE#SNX43-RW-TBH27 CHARGE AT THE ERECTION AND/OR CONSTRUCTION OF THE WORK. 33. ELECTRICAL CONTRACTOR SHALL PROVIDE CIRCUITS AND FINAL POWER CONNECTIONS FOR FIRE PROTECTION FLOW SWITCHES, TAMPER SWITCHES AND EMERGI-LITE#SNX43-RW-TBH27 9. UPON COMPLETION OF THE WORK, THE ELECTRICAL CONTRACTOR SHALL FUSED DISCONNECT SWITCH, SIZE AND RATING ALARM BELLS AS REQUIRED TO PROVIDE A FULLY FUNCTIONAL SYSTEM REVIEW AND CHECK THE ENTIRE PORTION OF WORK, CLEAN EQUIPMENT AND AS NOTED ON DRAWINGS DEVICES. REMOVE SURPLUS MATERIALS AND RUBBISH FROM THE VA'S PROPERTY. C24 EMERGI-LITE#SNX43-RW-TBH27 34. RECEPTACLES INDICATED FOR G.F.I. PROTECTION SHALL PROTECT NON-FUSED DISCONNECT SWITCH, SIZE AND LEAVING THE WORK IN NEAT AND CLEAN ORDER AND IN COMPLETE WORKING RECEPTACLE INDICATED ONLY. AT LOCATIONS WHERE G.F.I. RECEPTACLES RATING AS NOTED ON DRAWING CONDITION. THE ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR STAIRS ARE INDICATED WITHIN 5' OFA PLUMBING FIXTURE AND IN SIGHT OF EACH EMERGI-LITE#SNX43-RW-TBH27 REMOVAL OF ANY CARTON, DEBRIS, ETC. FOR EQUIPMENT INSTALLED BY THIS OTHER, ELECTRICAL CONTRACTOR MAY ELECT TO USE ONE "FEED THRU" G.F.I. CONTRACTOR INCLUDING EQUIPMENT FURNISHED BY THE VA. THE ABOVE SHALL THERMOSTAT JUNCTION BOX MOUNTED 54" A.F.F. UNLESS RECEPTACLE TO FEED "SLAVE" G.F.I. RECEPTACLE (S). G.F.I. CIRCUIT C20 EMERGI-LITE#SNX43-RW-TBH27 STAIRS ALSO APPLY TO ALL EQUIPMENT FURNISHED BY OTHERS AND UNPACKED OR OTHERWISE NOTED. BREAKERS WILL NOT BE PERMITTED TO PROTECT RECEPTACLES INDICATED FOR REMOVED FROM CARTON, BY THE ELECTRICAL CONTRACTOR. G.F.I. PROTECTION. C20 EMERGI-LITE#SNX43-RW-TBH27 THE ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR SCHEDULING DELIVERY, CEILING MOUNTED DUAL-TECHNOLOGY (PIR/ULTRASONIC) OCCUPANCY RECEIVING, UNLOADING, UNCRATING, STORING SETTING IN PLACE, AND ISENSOR. C23 EMERGI-LITE#SNX43-RW-TBH27 PROTECTING FROM DAMAGE, VANDALISM, THEFT OR WEATHER DURING CONSTRUCTION FOR ALL NEW EQUIPMENT FURNISHED BY THE ELECTRICAL CEILING FAN 11. THE ELECTRICAL CONTRACTOR SHALL PAY ALL PERMIT FEES, PLAN REVIEW EXIT SIGN - SEE EXIT SIGN SCHEDULE ELECTRICAL SYMBOL NOTES: FEES, LICENSE FEES, INSPECTIONS AND TAXES APPLICABLE TO THIS DIVISION, AS MAY BE REQUIRED, AND SHALL BE INCLUDED IN THE BASE BID AS PART OF THIS CONTRACT. WALL MOUNTED EMERGENCY BATTERY LIGHT FIXTURE 12. ELECTRICAL CONTRACTOR SHALL FURNISH AND INSTALL ALL TEMPORARY WIRING FOR HAND TOOLS AND CONSTRUCTION LIGHTING PER LATEST OSHA 1. ALL SWITCHES SHALL BE IVORY IN COLOR. 2 X 4 NIGHT LIGHT FIXTURE, 24 HOUR OPERATION STANDARDS AND INCLUDE ALL COSTS IN THE BASE BID. COORDINATE ALL REQUIREMENTS WITH THE GENERAL CONTRACTOR. 2. ALL RECEPTACLES SHALL BE IVORY IN COLOR AND MOUNTED AS FOLLOWS: 2 X 2 NIGHT LIGHT FIXTURE, 24 HOUR OPERATION NO SUBSCRIPT INDICATES MOUNTED HORIZONTALLY. 13. ELECTRICAL CONTRACTOR SHALL GUARANTEE ALL WORK AND MATERIALS "V" INDICATES MOUNTED VERTICALLY. AFTER THE FINAL ACCEPTANCE BY THE VA, IN ACCORDANCE WITH ALL OF THE PROJECT AND CONTRACTUAL REQUIRMENTS. 2 X 4 LIGHT FIXTURE 3. ALL COVER PLATES (SWITCHES, RECEPTACLES AND TELEPHONES) IN 14. ELECTRICAL CONTRACTOR SHALL FURNISH CONTRACT RECORD DOCUMENTS FINISHED AREAS SHALL BE STEEL, BRUSHED ALUMINUM FINISH. TO THE COR BEFORE FINAL PAYMENT WILL BE ISSUED. THE CONTRACT RECORD | | 2 X 2 LIGHT FIXTURE 4. ALL COVER PLATES (SWITCHES, RECEPTACLES AND TELEPHONES) IN DOCUMENTS SHALL DIAGRAMMATICALLY INDICATE THE INSTALLED CONDITION AND NON-FINISHED, EXPOSED AREAS SHALL BE IVORY CRACKLE FINISH. BE IN REPRODUCIBLE DRAWING FORM. DOWNLIGHT 15. THE ELECTRICAL INSTALLATION IS TO BE IN ACCORDANCE WITH ALL 5. ON ALL CONDUIT RUNS: ARROW INDICATE HOME RUN TO PANEL. NATIONAL, STATE, LOCAL ELECTRICAL CODES AND LOCAL UTILITY WALL MOUNTED LIGHT FIXTURE B. SLASHES INDICATE QUANTITY OF WIRES. COMPANY'S REQUIREMENTS. ANY MODIFICATION'S AND OR ADDITIONS TO THESE PLANS, REQUIRED FOR PROPER COMPLIANCE TO ANY APPLICABLE CODES SHORT SLASHES INDICATE PHASE AND SWITCH LEGS... UNDER-CABINET TASK LIGHT SHALL BE THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR AND SHALL LONG SLASHES INDICATE NEUTRAL CONDUCTORS.. BE INCLUDED IN HIS HER BASE BID. LONG SLASHES WITH DOT INDICATE GREEN GROUND ELECTRIC HAND DRYER CONDUCTORS. W LARGE COMPARTMENT METAL RACEWAY 16. ALL EQUIPMENT/DEVICES SHALL BE NEW AND/OR FIRST QUALITY AND IS TO BEAR THE APPROPRIATE UL OR CSA APPROVED LABELS FOR SPECIFIC AT LOCATIONS INDICATED ON DRAWINGS. (JB) JUNCTION BOX ADO AUTOMATIC DOOR OPENER (24V CONTROLS) CR | CARD SWIPE/READER PP PUSH PLATE ES | ELECTRONIC STRIKE

IDIQ NO. VA69D-13-D-0042

SELECTIVE PROPRIETARY VENDORS

VENDOR INFORMATION


ENORMAN SECURITY SYSTEMS INC.


SIEMENS FIRE ALARM SYSTEM


ADVENT SYSTEMS, INC.

JOHNSON CONTROLS

CONTRACT NO. VA69D-14-J-3280 Project Title Project Number Drawing Title SITE PLAN: ENGINEERS + CONSULTANTS: ARCHITECT + ENGINEERS: Office of ELECTRICAL NOTES AND SYMBOLS INTERIOR ARCHITECTURAL #537-13-122 CONSTRUCTION AT BUILDING 5 Building Number Construction and Facilities 700 Nicholas Blvd. Suite 403 Approved: Project Director Location Drawing Number Management Elk Grove Village, IL 60007 | CHICAGO. IL T:847.952.9362 F:847.952.9403 E-001 ISSUED FOR SOLICITATION 08/04/2016 Checked Drawn www.bancroft-ae.com BANCROFT ARCHITECTS + ENGINEERS **©** Department of 12/03/2015 Bancroft-AE Project No. 13-105-08 ISSUED FOR BIDS ||12/03/2015 CD Date Revisions: TAYLOR STREET VA FORM 08-6231







— .
